

The School at McGuire Memorial

2121 Mercer Road • New Brighton, PA 15066
724-891-7222

Feb. 23, 2023

Dear School at McGuire Memorial Community,

As a part of The School at McGuire Memorial's effort to provide students and staff with safe and accessible drinking water, 28 water outlets at the school were tested for lead on Dec. 22, 2022, and one additional water outlet was tested on Feb. 8, 2023. A trained technician collected samples from water outlets and the samples were sent to an accredited Pennsylvania laboratory for analysis.

Test results showed all outlets were found to have no detectable lead in water. As such no further action is necessary to provide safe drinking water to our students and staff at this time. All test results are shown on the attached page.

If there are any further actions taken on our part, more information will be sent to you at that time.

If you have any questions about lead in drinking water and impacts to children's health visit www.pennvestleadtestingprogram.com or you may contact me at any time. Other resources at your disposal are the Department of Health (DOH) Lead Information Line, 1-800-440-LEAD and the Department of Environmental Protection (DEP), Bureau of Safe Drinking Water (BSDW), Resource account, RA-EPWIINLEAD@pa.gov and phone number: 717-787-9633.

Sincerely,



Dr. Kim Lieb
Chief School Administrator



The School at McGuire Memorial Lead Test Results 2022-23

Sample Results

Sample Date	Sample Id	Outlet Description	Lead Result (ppb)	Action Limit (15 ppb)
12-22-2022	1513	Bathroom Faucet; Hall Restroom Next to Room 115	< 1	Below
12-22-2022	1514	Bathroom Faucet; Staff Restroom Next to RM 112	< 1	Below
12-22-2022	1515	Bathroom Faucet; Room 112 Restroom	< 1	Below
12-22-2022	1516	Bathroom Faucet; Room 116 Restroom	< 1	Below
12-22-2022	1517	Bathroom Faucet; Men's Restroom Next to RM 116	1.2	Below
12-22-2022	1518	Bathroom Faucet; Women's Restroom Next to RM 111	1.4	Below
12-22-2022	1519	Bathroom Faucet; Room 111 Restroom	1.7	Below
12-22-2022	1520	Bathroom Faucet; Room 117 Restroom	< 1	Below
12-22-2022	1521	Classroom Faucet; Room 110 Sink	< 1	Below
12-22-2022	1522	Classroom Faucet; Room 109 Sink Under Window	< 1	Below
12-22-2022	1523	Bathroom Faucet; Private Restroom Next to RM107	9.2	Below
12-22-2022	1524	Water Fountain ; WF Next to 246 Storage	< 1	Below
12-22-2022	1525	Bathroom Faucet; Women's Next to 246 Storage Mid	4.6	Below
12-22-2022	1526	Bathroom Faucet; Men's BR Next to 246 Storage	< 1	Below
12-22-2022	1527	Bathroom Faucet; Restroom Front Lobby	< 1	Below
12-22-2022	1528	Water Fountain ; WF Next to Room 221 Kitchen	< 1	Below
12-22-2022	1529	Bathroom Faucet; Room 244 Restroom	< 1	Below
12-22-2022	1530	Bathroom Faucet; Room 243 Restroom	1.8	Below
12-22-2022	1531	Bathroom Faucet; Room 240 Restroom	< 1	Below
12-22-2022	1532	Bathroom Faucet; Room 239 Restroom	1.1	Below
12-22-2022	1533	Bathroom Faucet; Room 227 Restroom	< 1	Below
12-22-2022	1534	Bathroom Faucet; Room 228 Restroom	< 1	Below
12-22-2022	1535	Bathroom Faucet; Restroom Next to Room 238	< 1	Below
12-22-2022	1536	Bathroom Faucet; Room 236 Restroom	< 1	Below
12-22-2022	1537	Bathroom Faucet; Room 235 Restroom	< 1	Below
12-22-2022	1538	Bathroom Faucet; Room 233 Restroom	< 1	Below
12-22-2022	1539	Classroom Faucet; Room 232 Sink	< 1	Below
02-07-2023	1540	Water Fountain ; WF Life Academy	< 1	Below
12-22-2022	1541	Kitchen Faucet; RM 221 Kitchen Big Sink	< 1	Below

Notes:

< - not detected above detection limit

ppb - parts per billion